


Residual Current Breakers Operated RCBO 6-50A

6LE007134Ab



WARNING:
Installation by qualified installers only





A warranty period of 24 months is offered on hager products, from date of manufacture, relating to any material of manufacturing defect.

If any product is found to be defective it must be returned via the installer and supplier (wholesaler).






The warranty is withdrawn if :

- after inspection by hager quality control dept the device is found to have been installed in a manner which is contrary to IEE wiring regulations and accepted practice within the industry at the time of installations.
- the procedure for the return of goods has not been followed. Explanation of defect must be included when returning goods.



OFF

ON



Note:
With the device in the OFF position, insulation resistance test can be carried out on the load terminals of this product without disconnecting the RCBO.